

Einstellwerte für Ventil Clack WS1CI-1" / 1,5" / 2"									MK-10/19
Berechnung mit Chrystal-Right CR 100				ph-Wert größer 5,7					
			Ventil-Einstellung 			Zyklen-Einstellung			
Flaschen Größe	Harzmenge Liter	Kap.	Injektor	BLFC	DLFC	Spülen / min.	Besalzen, langsam spülen / min.	Schnell spülen / min.	Soletank füllen / kg
1044	28,3	42	brown	0,5	3,2	16	90	4	4,1
1054	42,5	75	violet	0,5	4,2	16	90	4	5,5
1354	71,8	122	red	0,5	7,5	16	90	4	8,2
1465	99	167	white	0,5	10	16	90	4	10,9
1665	127	214	yellow	0,5	11	16	90	4	13,7
1865	170	287	orange	0,5	15	16	90	6	21,9
2160-1 1/2"	198	334	light blue	0,5	20	16	90	4	32,8
2469-1 1/2"	311	524		1	25	18	90	6	54,7
3072-2"	538	907				18	90	8	54,7
Regeneration spätestens am 3. Tag									